

No: PHI/Water/BAC/68/2026-27 GOVERNMENT OF KARNATAK

Office of Joint Director
Public Health Institute,
Bengaluru - 560001

Report of Bacteriological analysis of Water Sample

Date: 04/04/2026

Principal Sri Chaitanya Techno School NO 93/2 A3 93/2A4 93/10A 93/11 Marathahalli Munnokolala Village Bangalore-560037	Opinion							
	Sample No	Source & Particulars of Water Sample	M.P.N Count	Plate Count	D.C. Test	S.P.P	N.S.P.P	N.S.P.P & FC
Note: M.P.N. Count: Most Potable number of Bacteria Per 100ml of Water D.C Test: Differential Coliform test Plate Count: Plate Count per ml of sample SPP: Water is satisfactory for Potable purpose NSPP: Water is not satisfactory for Drinking purpose NSPP & FC: Water is not satisfactory for Drinking purpose and E. Coll found	195	Drinking Water	Nil	-	-	SPP	-	-

NEXGEN EDUCATIONAL TRUST

Authorized Signature

PRINCIPAL
SRI CHAITANYA TECHNO SCHOOL
90/10, 90/11, 93/2A3, 93/2A4,
Beside Shanmukha Restaurant
ORR Service Road, Marathahalli-2,
Bengaluru - 560 037
Ph: 7022602889 / 9071766539

For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE,
Bengaluru

(PTO)

Advice: 1. Sample

Need effective chlorination before

2. Sample

Need to avoid possible source of faecal contamination and effective chlorination before use for the purpose of Chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform Count Per 100 ml	E Coli Count Per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More

NEXGEN EDUCATIONAL TRUST

Authorized Signature

Principal
SRI CHAITANYA TECHNO SCHOOL
90/10, 90/11, 93/2A3, 93/2A4,
Beside Shanmukha Restaurant
ORR Service Road, Marathahalli-2.
560 037

